

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/SZ/2023/209

Dated: 24/03/2023

FIRE SAFETY CERTIFICATE

Certified that **Salwan Public School** located at **Girdhari Lal Salwan Marg, Rajendra Nagar, New Delhi- 110060**, having five blocks namely Block- A, Block-B, Block-D, Block-E & Block-F. Block- A, E & F are comprised of ground floor plus one upper floor. Block B & Block D are comprised of ground plus two upper floors, was issued Fire Safety Certificate vide this department No. F.6/DFS/MS/School/SZ/2020/224 dated 15.07.2020. The school building was re-inspected by the concerned officer of Delhi Fire Service on 13.03.2023 in the presence of Sh. Kallu Singh (admin officer) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 under Delhi Fire Service Act- 2007 and found that the school complex (**Block- A, Block-B, Block-D, Block-E & Block-F**) (**Except Block- C & M.P Hall**) is fit for occupancy class "Educational" with effect from 24/03/2023 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 24/03/2023 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Principal, Salwan Public School, Rajendra Nagar, New Delhi- 110060.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Salwan Public School, Girdhari Lal Salwan Marg, Rajendra Nagar, New Delhi- 110060.
2. Type of Occupancy : Educational
3. Building Composition : The School building complex is comprised of five blocks. Block A, E & F (ground plus one upper floor each), Block-B & D (ground plus two upper floors each).
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/SZ/2020/224 dated 15.07.2020
6. Fire Safety directives letter No : Dt. of Education circular no. 262-362 dt. 17.01.2005
7. Date of inspection : 13.03.2023
8. Name of the Inspecting Officers : P.V. Rathee, ADO(SRD)
9. Name and designation of officers from the building side : Mr. Kallu Singh (Admin Officer)
9. Year of Construction : Before 2007 (1956, 1970) as per previous inspection Performa
10. Applicant's letter No. : Email ID spsaf5033@salwanpublicschool.com dt. 10.03.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per FSC dt. 15.07.2020	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided (9.0 mts)	MR
	• Gate width	Old Case	390 cms x 02 nos	MR being old case
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	2 each block	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts or less & 0.75 mt	Block A- 1.52, 1.47, Block B- 1.47, 1.50 mts, Block D- 1.35, 0.92 mts, Block E- 1.50, 1.49, Block F- 1.54, 0.68-1.30 mts.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 each block	Provided	MR
	g. Width of Corridor	150 Cms	165, 215, 235 Cms	MR
	h. Door Size	1.0 mt	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested / checked and found satisfactory at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/SZ/2020/224 dated 15.07.2020, renewal under Rule 37 of Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.

D.O (SW)

15/08/23

CFD (S2)

17/08/2023

Dineela

17/08/23

17/08/23

15/08/23

(P.V. Rathee)

Asstt. Div. Officer (SRD)