

MUNICIPAL CORPORATION OF DELHI

(Office of the Sanitation Superintendent)
Department of Environment management services
Karol Bagh Zone

No. 2670


Date: 8/11/24

SCHOOL SANITATION CERTIFICATE

- | | | |
|-----------------------------------------------------------------------------------------------|---|-------------------------------------------------------------------|
| 1. Name of the School | : | Salwan Public School |
| 2. Location | : | Pt. Girdhari Lal Salwan Marg,
Rajinder Nagar, New Delhi-110060 |
| 3. Date of Inspection | : | 24/10/2024 |
| 4. No. of Students | : | 3505 |
| 5. Accommodation clean Yes/No | : | Yes |
| 6. Clean rooms calculated | : | 96 Rooms |
| 7. Floor space in sufficient or not | : | Yes |
| 8. All Classrooms are well lighted or not | : | Well Lighted |
| 9. Drinking water is wholesome or not | : | Wholesome |
| 10. Adequate arrangement of Toilet
Facility Yes/No | : | Yes |
| 11. Toilets are properly cleaned, Hygiene
or not | : | Yes, cleaned/Hygienic |
| 12. Source segregation of Dry Wet and
Hazardous waste done or not | : | Yes |
| 13. On site wet waste composting Yes or Not | : | Yes |
| 14. Awareness of Single use plastic arranges
all the Children done on regular basis or not | : | Yes on regular basis |
| 15. Arrangements of Separate Collection of
Plastic waste Yes/No | : | Yes |


REMARKS:-

The School is found neat and clean and fit from sanitation point of view. Therefore, NOC is granted.


Sanitation Superintendent
Karol Bagh Zone



**DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54**



TEST REPORT

Sample ID	Ref. No. D.J:B/DTQC/Wzd./2024-25/Paid-133-136		
Location /Address of Sample	Salwan Public School, Girdharilal Salwan Marg, Rajender Nagar, New Delhi-110060		
Letter Reference No.	SPS/547/2024	Ref. Letter Date	27.09.2024
Challan No.	165	Challan Date	03.10.2024
Sample Collection date	04.10.2024	Analysis start date	04.10.2024
Any other Information	--	Analysis end date	06.10.2024
		Reporting date	09.10.2024

TEST RESULTS

S.N	Parameters	Unit	As per the IS 10500		Inlet No. 1 (Under Ground Storage Tank)	Inlet No. 2 (Under Ground Storage Tank)	Outlet RO No 1	Outlet RO No 2
			Acceptable limit	Permissible limit				
1	Colour	CU	5 (Max)	15 (Max)	2.0	2.0	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	3.9	3.0	2.0	1.9
4	pH at 25 °C	--	6.5-8.5	No relaxation	7.25	7.24	6.82	7.0
5	Electrical Conductivity	µS/cm	-	-	1007	998	103	38
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	654	648	67	25
7	Total Alkalinity	mg/L	200(Max)	600(Max)	274	266	36	12
8	Total Hardness	mg/L	200(Max)	600(Max)	330	306	38	8
9	Calcium	mg/L	75(Max)	200(Max)	86	82	8	1.6
10	Magnesium	mg/L	30(Max)	100(Max)	28	24	4.3	0.96
11	Iron	mg/L	1.0(Max)	No relaxation	0.12	0.12	0.02	0.02
12	Chloride	mg/L	250(Max)	1000(Max)	110	140	12	6
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.20	0.18	0.02	BDL
14	Ammonical-N	mg/L	0.5(Max)	No relaxation	BDL	BDL	BDL	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	41.2	41.2	4.8	0.9
16	Sulphate	mg/L	200(Max)	400(Max)	73.6	73.4	4.1	0.4
17	Residual Chlorine	mg/L	0.2 (Min.)	1.0(Max)	BDL	BDL	BDL	BDL
18	Coliform Count at 37° (MPN)	/100 mL	Absent	No relaxation	0	0	0	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: For the tested parameters the water sample collected from water cooler (RO) conforms specification and can be considered for the drinking purpose.

[Signature]
Tested by
Lab.Tech.

[Signature]
Verified for Chemical parameters
Asstt. Chemist

[Signature]
Verified for MPN
Asstt. Bact.

[Signature]
Authorized by
Chemist /AGWA/Wzdyst
Asstt. Chief Water
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad

[Signature]
15/10/24

Submitted for information please
Adwar Sir *[Signature]*

15-10-24